

**TEST REPORT No. 267 SF/24 R**

**Date: 4th of November 2024**

page (pages)

1(6)

**Test methods:**

**LST EN ISO 22097:2023** Thermal insulation for buildings - Reflective insulation products - Determination of thermal performance.

**LST EN 12667:2002** Thermal performance of building materials and products - Determination of thermal resistance by means of guarded hot plate and heat flow meter methods - Products of high and medium thermal resistance.

**Test method** – heat flow meter.

**Type and identification of apparatus** – symmetrical single-specimen apparatus No. 1/99 (ISO 8301).

(number of normative document or test method, description of test procedure, test uncertainty)

**Customer:**

SAS ATI FRANCE, SAS ATI FRANCE, Parc industriel de la Plaine de l'Aine - 1  
Avenue des Troussilières- 01150 BLYES, France

(name and address)

**Manufacturer:**

SAS ATI FRANCE, SAS ATI FRANCE, Parc industriel de la Plaine de l'Aine - 1  
Avenue des Troussilières- 01150 BLYES, France

(name and address)

**Samples description:**

Type 2 multilayer reflective insulation **Buld'Oz'Air**, 600×600mm; Declared thickness of product 12±2mm.

(name, description and identification details of a specimen)

**Samples selected:**

By customer

(who selected/place/date)

**Samples delivery date:**

29/10/2024

**Place of samples  
conditioning:**

Building Physics Laboratory, Institute of Architecture and Construction Kaunas  
University of Technology, Tunelio st. 60, LT 44451 Kaunas, Lithuania

(name and address)

**Samples conditioning  
date:**

29/10/2024 – 30/10/2024

**Date of testing:** 30/10/2024 – 31/10/2024

**Production date:**

no data

**Tested at:**

Building Physics Laboratory IAC KTU

(name and address)

**Test results:**

Name of the indicator and unit	Test method reference no.	Test result
Declared core thermal resistance of product <b>Buld'Oz'Air</b> , $R_{D(core)90/90}$ , (m <sup>2</sup> ·K)/W	LST EN ISO 22097:2023	<b>0.29</b>
Declared thermal resistance of system with 2 air gaps $R_{system 90/90}$ , (m <sup>2</sup> ·K)/W		<b>1.60</b>

**Additional  
information:**

Mean ambience temperature 10.00 °C,  
Ambience relative humidity 65.0 %.

**Annexes:**

**Annex 1.** Tests results; **Annex 2.** Calculation of declared thermal resistance; **Annex 3.** Calculation of thermal resistance including associated airspaces; **Annex 4.** The parameters of heat flow meter apparatus.

Technical manager:

(approves the test results)

Lietuvos Respublika

(signature)

J. Ramanauskas

(n., surname)

Tested by:

(technically responsible for testing)

DOKUMENTAI

S.P.

(signature)

A. Burlingis

(n., surname)

Validity – the named data and results refer exclusively to the tested and described specimens.

Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 1. Tests results:**

**Specimen No. 267-1/24**

<b>Heat flow direction – vertical</b>		
<b>Conditioning of sample – Climate chamber 48 h, <math>T = 23 \pm 2^\circ\text{C}</math>, <math>\text{RH} = 50 \pm 5\%</math>.</b>		
<b>Testing parameters</b>	<b>unit</b>	<b>Value</b>
Temperature of hot plate, $T(h)$	$^\circ\text{C}$	20.02
Temperature of cold plate, $T(c)$	$^\circ\text{C}$	0.02
Density of heat flow of hot plate, $q(h)$	$\text{W}/\text{m}^2$	31.51
Density of heat flow of cold plate, $q(c)$	$\text{W}/\text{m}^2$	32.61
Mean density of heat flow through the specimen, $q$	$\text{W}/\text{m}^2$	31.06
Mean temperature of specimen, $T$	$^\circ\text{C}$	10.02
Mean thermal conductivity, $\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	<b>0.04181</b>
Uncertainty of the measurement, $\Delta\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	$\pm 0.000182$
Core thermal resistance, $R_c$	$(\text{m}^2\cdot\text{K})/\text{W}$	<b>0.64389</b>
Uncertainty of the measurement, $\Delta R$	$\text{m}^2\cdot\text{K}/\text{W}$	$\pm 0.0024$

**Specimen No. 267-2/24**

<b>Heat flow direction – vertical</b>		
<b>Conditioning of sample – Climate chamber 48 h, <math>T = 23 \pm 2^\circ\text{C}</math>, <math>\text{RH} = 50 \pm 5\%</math>.</b>		
<b>Testing parameters</b>	<b>unit</b>	<b>Value</b>
Temperature of hot plate, $T(h)$	$^\circ\text{C}$	20.02
Temperature of cold plate, $T(c)$	$^\circ\text{C}$	0.01
Density of heat flow of hot plate, $q(h)$	$\text{W}/\text{m}^2$	32.24
Density of heat flow of cold plate, $q(c)$	$\text{W}/\text{m}^2$	31.58
Mean density of heat flow through the specimen, $q$	$\text{W}/\text{m}^2$	31.91
Mean temperature of specimen, $T$	$^\circ\text{C}$	10.02
Mean thermal conductivity, $\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	<b>0.04205</b>
Uncertainty of the measurement, $\Delta\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	$\pm 0.000181$
Core thermal resistance, $R_c$	$(\text{m}^2\cdot\text{K})/\text{W}$	<b>0.62713</b>
Uncertainty of the measurement, $\Delta R$	$\text{m}^2\cdot\text{K}/\text{W}$	$\pm 0.0023$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Specimen No. 267-3/24**

<b>Heat flow direction – vertical</b>		
<b>Conditioning of sample – Climate chamber 48 h, <math>T = 23 \pm 2^\circ\text{C}</math>, <math>\text{RH} = 50 \pm 5\%</math>.</b>		
<b>Testing parameters</b>	<b>unit</b>	<b>Value</b>
Temperature of hot plate, $T(h)$	$^\circ\text{C}$	20.02
Temperature of cold plate, $T(c)$	$^\circ\text{C}$	0.02
Density of heat flow of hot plate, $q(h)$	$\text{W}/\text{m}^2$	33.15
Density of heat flow of cold plate, $q(c)$	$\text{W}/\text{m}^2$	32.24
Mean density of heat flow through the specimen, $q$	$\text{W}/\text{m}^2$	32.70
Mean temperature of specimen, $T$	$^\circ\text{C}$	10.02
Mean thermal conductivity, $\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	<b>0.04278</b>
Uncertainty of the measurement, $\Delta\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	$\pm 0.000182$
Core thermal resistance, $R_c$	$(\text{m}^2\cdot\text{K})/\text{W}$	<b>0.61168</b>
Uncertainty of the measurement, $\Delta R$	$\text{m}^2\cdot\text{K}/\text{W}$	$\pm 0.0022$

**Specimen No. 267-4/24**

<b>Heat flow direction – vertical</b>		
<b>Conditioning of sample – Climate chamber 48 h, <math>T = 23 \pm 2^\circ\text{C}</math>, <math>\text{RH} = 50 \pm 5\%</math>.</b>		
<b>Testing parameters</b>	<b>unit</b>	<b>Value</b>
Temperature of hot plate, $T(h)$	$^\circ\text{C}$	20.02
Temperature of cold plate, $T(c)$	$^\circ\text{C}$	0.02
Density of heat flow of hot plate, $q(h)$	$\text{W}/\text{m}^2$	32.19
Density of heat flow of cold plate, $q(c)$	$\text{W}/\text{m}^2$	31.30
Mean density of heat flow through the specimen, $q$	$\text{W}/\text{m}^2$	31.73
Mean temperature of specimen, $T$	$^\circ\text{C}$	10.02
Mean thermal conductivity, $\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	<b>0.04247</b>
Uncertainty of the measurement, $\Delta\lambda$	$\text{W}/(\text{m}\cdot\text{K})$	$\pm 0.000183$
Core thermal resistance, $R_c$	$(\text{m}^2\cdot\text{K})/\text{W}$	<b>0.63033</b>
Uncertainty of the measurement, $\Delta R$	$\text{m}^2\cdot\text{K}/\text{W}$	$\pm 0.0023$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 2. Calculation of declared thermal resistance**

Sample No.	Core thermal resistance of double sample, $R_c$	Effective thermal conductivity, $\lambda$	Thickness of double sample, mm
1	0.643888	0.0418085	26.92
2	0.627129	0.0420488	26.37
3	0.611684	0.0427835	26.17
4	0.630327	0.0424700	26.77
<i>Average:</i>	<b>0.6283</b>	<b>0.0423</b>	<b>26.56</b>

Sample size: 600 x 600 mm.

**Declared derived R-value of double insulation product:**

$$S_{R(\text{core})} = \sqrt{\frac{\sum (R_i - R_{\text{average}})^2}{n - 1}};$$

$$S_{R(\text{core})} = 0.01557;$$

$$R_{D(\text{core})90/90} = R_{\text{average}} - k_2 \cdot S_{R(\text{core})};$$

$$k_2 = 3.19$$

$$R_{D(\text{core})90/90} = 0.59173 = 0.59 \text{ m}^2 \cdot \text{K/W}$$

**Declared thermal resistance of the core  $R_{D(\text{core})}$  of one insulation product**

$$R_{D(\text{core})90/90} = 0.59173/2 = 0.29586 = 0.29 \text{ m}^2 \cdot \text{K/W}$$

***Annex 3. Calculation of thermal resistance including associated airspaces according EN 16863 Annex D and EN ISO 6946:***

- Declared emissivity of the product surfaces 0.05;
- Temperature difference across each air cavity of 5K, mean temperature of 10°C;
- Thermal resistance of one air gaps 0.6640 m<sup>2</sup>·K/W;
- Thermal resistance of two air gaps 1.3280 m<sup>2</sup>·K/W;

***Calculation of thermal resistance including two vertical airspaces:***


Air gap 20 mm – Product - Air gap 20 mm

$$R_{D(system) 90/90} = 0.29586 + 1.3280 = 1.62386 = 1.60 \text{ m}^2 \cdot \text{K/W}$$

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.

**Annex 4. The parameters of heat flow meter apparatus:**

SCHEME OF HEAT FLOW METER APPARATUS  
Single specimen symmetrical configuration apparatus



- |                                       |   |
|---------------------------------------|---|
| 1 – Specimen under testing;           | 7 – Heat flow meter at cooling plate;     |
| 2 – Cooling plate;                    | 8 – Thermo-couple;                        |
| 3 – Heating plate;                    | 9 – Guarded space,                        |
| 4 – Cooling thermostat;               | 10 – Surrounding with controlled constant |
| 5 – Heating thermostat;               | temperature.                              |
| 6 – Heat flow meter at heating plate; |   |

**Notes:**

- Specimen dimensions 600 x 600 mm, central measuring area of heat flow meter 250 x 250 mm.
- Possibility to measure under various heat flow directions: horizontal, upwards, downwards, on different angles with horizontal plane.
- Used edge heat losses reduction methods:
  - Specimen thickness limitation (to 150 mm);
  - Controlled ambient temperature during the test equal to the mean specimen temperature.

Validity – the named data and results refer exclusively to the tested and described specimens.  
Notes on publication – no part of this document may be photocopied, reproduced or translated to another language without the prior written consent of the Laboratory of Building Physics.